

Note: 1. The outcome cooling capacity is calculated in accordance with the running process of inlet chilled water temperature 12°C and outlet water temperature 7°C. Inlet cooling air temperature 30°C and outlet air temperature 40°C.
2. Working condition: Chilled water temperature ranges from 5°C to 35°C. Temperature difference between inlet and outlet chilled water is 3°C to 8°C. Setting temperature recommended is not higher than 35°C. Temperature difference between inlet and outlet chilling air is 3°C to 8°C.